



Chhatrapati Sambhajinagar Municipal Corporation
FIRE BRIGADE
TELEPHONE NO-2334000-40FAX No-2331444

Outward No AMC/FIRE / 15 /2025

Date 02/03/2025

To,
Principal,
Little Wonders English School,
S.No. 373, Jalgaon Road, Sillod,
Dist. Chhatrapati Sambhajinagar.

Sub:- Provisional Fire NOC is Issued to the Principal, Little Wonders English School, S.No. 373, Jalgaon Road, Sillod, Dist. Chhatrapati Sambhajinagar.

Ref:- 1. Your Letter on date 20/03/2025 2) S/o. Inspection on date 24/03/2025

With Reference to the above subject Provisional Fire NOC is issued to the Principal, Little Wonders English School, S.No. 373, Jalgaon Road, Sillod, Dist. Chhatrapati Sambhajinagar. Plot area is 24700.00 Sq.mtr.

Owner has paid Fire Fund Fees Rs 291000/- & Provisional Noc Rs. 10000/- Total Rs . 301000/- in Fire brigade Receipt No. 12709 dated on 24/03/2025.

S. No	Building Type	Height of Building Mtr	No. of Building	Floors	Area Of Plot	Builtup Area Sq.Mtr	Fire Fund Rs	Noc Fees Rs.
1	Little Wonders English School	10.97 Mtr	1	G+2	24700.00 Sq.mtr	3000.00 Sq.mtr Per Sq.mtr 97/- 291000	291000	10000

Following Fire prevention and Fire protection & Fire Fighting measures subject to the Little Wonders English School shall be provided.

1. Open space all around the building shall be provided for the movement of fire tender and which will carry 25 tons. weight capacity.
2. Overhead water tank 25000 lit capacity with the Main fire pump- 900 LPM-02 Nos capacity for building shall be provided.
3. Fire service inlet 2 way incoming shall be provided.
4. Yard Hydrant points all around the building with fire hose pipe/ branch shall be provided.
5. Wet –riser having outlet on all floors with hose pipe / branch shall be provided.
6. Hose reel of 100 feet on all outlets shall be provided.
7. Main Staircase 2.00 Mtr shall be provided.
8. Fire Extinguisher of / ABC/ Co2/ Fire Buckets of suitable capacity / quantity & Fire Chut shall be provided.
9. All the fire fighting equipments shall be well maintained and should be easily accessible in case of emergency.
10. It shall be ensured that security staff & every employee of the building are trained in handling fire fighting equipments & fire fighting.
11. Fire Extinguisher, Fire Bucket, Danger, No Smoking, Caution boards should be displayed at the places physically shown & the caution boards should be easily visible from a distance.

- 12 The Fire Safety requirements of IS 3594 i.e. Code of practice for fire safety of Highrise Building shall be followed.
- 13 Emergency Telephone numbers like Police, Fire Brigade, Hospital, Doctors, should be displayed in security cabin & Office of the building.
- 14 Use of all Pipes of TATA Zenith or APL (APPOLO) or ISI Mark for Fire Down comer system shall be Provided
- 15 All the above requirements shall be carried out with prior approval from fire Brigade.

The Fire Fighting System arrangements installed for Existing area Hose Reel Hose, Fire Extinguishers, should be extended to the proposed construction and also integrated with the existing system.

Sr. No.	Fire Fighting Installation	Requirements	Provision	Remarks
1	Portable Fire Extinguishers	Required	IS: 15683 & IS: 2190	Portable Fire Extinguisher should be installed Confirming to IS 15683 & Other IS Codes
2	Hose Reel	Required Prominent Places	At Various Strategic Locations	On each floor in the Staircase landing for fire fighting. The first aid hose reel shall be connected directly to riser/Down comer main and diameter of the hose reel shall not be less than 19 mm Confirming to IS 884:1985
3	Booster Pump	Existing Pumps shall be used	Fire Fighting pumps shall be well maintained. A Separate arrangement of pumping should be done for Sprinkler system. All the Fire pumps must be centrifugal pumps only.	

As per BPMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention & Life safety Measures Act 2006. Provisional Fire NOC is issued to the Principal, Little Wonders English School, S.No. 373, Jalgaon Road, Sillod, Dist. Chhatrapati Sambhajinagar.


Chief Fire Officer
Fire Brigade, Municipal Corporation,
Chhatrapati Sambhajinagar.

Copy to:- A D.T.P AMC, Chhatrapati Sambhajinagar.


-
MANAGER

Little Wonders English School
Sillod, Dist. Chh. Sambhajinagar


PRINCIPAL
Little Wonders English
School
Sillod, Dist. Chh. Sambhajinagar